

RHV Hallstättersee			Kläranlage Bad Goisern										Jahresprotokoll 2023			
Monat	Zulauf- menge	Abwasser- temperatur	BSB ₅			CSB			NH ₄ -N		NO ₃ -N	N _{ges.}	ges. P			Belastung
			Zulauf	Ablauf	Abbau	Zulauf	Ablauf	Abbau	Zulauf	Ablauf	Ablauf	Abbau	Zulauf	Ablauf	Abbau	
	[m ³]	[°C]	[mg/l]	[mg/l]	[%]	[mg/l]	[mg/l]	[%]	[mg/l]	[mg/l]	[mg/l]	[%]	[mg/l]	[mg/l]	[%]	EW-BSB ₅
Jänner	113 512	8,8	343	6,0	98,3	692	28,0	95,7	38,3	4,8	12,9	72,3	8,0	0,5	93,7	18 929
Februar	124 605	7,8	270	6,0	97,6	572	25,0	95,7	36,0	4,9	11,4	71,8	6,9	0,4	93,7	17 593
März																
April																
Mai																
Juni																
Juli																
August																
September																
Oktober																
November																
Dezember																
Summe	238 117															
Ø	119 059	8,3	307	6,0	98,0	632	26,5	95,7	37,2	4,9	12,2	72,1	7,5	0,5	93,7	18 261

Legende

BSB₅ Biochemischer Sauerstoffbedarf
 CSB Chemischer Sauerstoffbedarf
 NH₄-N Ammoniumstickstoff
 NO₃-N Nitratstickstoff

ges. P gesamt Phosphor
 EW Einwohnerwerte